

Running Contract Details	
Equipment Name	Fire Extinguisher - CO2 Type
Running Contract Valid Till	12-02-2025
Tender Ref No	KMSCL/EP/T468/322A/2022
Tendered Quantity	50
Supplier Name	M/s USHA FIRE TECH
GST No	32CNIPS6982G1ZI
Installation & Delivery Period	6 Week(s)
Up-time / PM vist	95% & 2 Visits per year
Warranty period	1 Years

Supplier`s Details		
Address	Contact Details	
Sumisha Arcade Murari Lane Kaithamukku Pettah P.O-695024	Contact Person	Arun Kumar
	Phone	+91-471-3500993
	Mobile No	+91-9048413450
	Email	contact@ushas.in

Item-wise Price Details				
#	Item Details	Unit Rate (Incl.all taxes & charges)	Service Charges (Through KMSCL)	Grand Total
1	Fire Extinguisher - CO2 Type <i>Model & Make : Fire Extinguisher â€™ CO2 Type / Safepro Fire Services Pvt Ltd</i>	7632.24 Incl.GST :18%	534.26	8166.5
		7632.24	534.26	8166.5

Other terms & conditions

1. The supplier shall execute an agreement with the purchaser as per tender conditions (agreement format is given in the tender document).
2. The supplier shall submit performance security amounting to 5.00% of the value of the supply order.
3. The labour & comprehensive charges of equipment after the completion of warranty period is finalized by KMSCL as mentioned above.
4. Since discount rate is not applicable for equipment under Running Contract of KMSCL, purchase/supply order can be issued directly to supplier at the given rate with tax & other charges (exclusive of KMSCL service charges).

5. If purchase/supply order is issued directly to the supplier, KMSCL service charge need not be paid. But the copy of the said order may be forwarded to KMSCL for information.

Technical Specification

Equipment :Fire Extinguisher - CO2 Type

1. Should have a capacity of at least 6kg.
2. Should be applicable for Class B and C fires.
3. Should be mounted on a Trolley for easy movement.
4. Extinguishing Agent shall be Carbon dioxide Gas.
5. Should have Squeeze grip for easy operation and no hand injuries due to ice freezing.
6. Should have controllable discharge mechanism.
7. Should have a minimum throwing distance of 2 meters for extinguishing agent.
8. Should have ISI Certification.
9. The sheet metal should have a thickness of at least 4.5mm
10. Should have warranty for at least 1 Year.
11. Any refill required for the unused cylinders during the warranty period shall be done free of cost.
12. The pressure maintained inside the extinguisher should be 10 bars